

Notified Body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

**Certificate of Constancy of Performance,
1121-CPR-MA5002**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Heavy Duty Steel Security/Fire Exit Doorset
Intended use:- Single leaf external pedestrian panic exit doorsets

Essential characteristics	Performance	Harmonised technical specification
Watertightness – Non-shielded (A)	NPD	EN 14351-1:2006 +A1:2010
Watertightness – Shielded (B)	NPD	
Dangerous substances	None	
Resistance to wind load – Test pressure	NPD	
Resistance to wind load – Frame deflection	NPD	
Load bearing capacity of safety devices	NPD	
Height	1975mm	
Acoustic performance	NPD	
Thermal transmittance	2.2 W/m ² K	
Air Permeability	NPD	
Ability to Release	EN 1125, EN 179 & EN 1935	

Produced for:

Network Product Marketing Ltd T/A Doors For Security
Unit 11, Greenfield Farm Trading Estate, Greenfield Road, Congleton, Cheshire,
CW12 4TR, UK

and produced in the manufacturing plant (s)
J/041 & E/065

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 14351-1:2006 + A1:2010

under system 1 of AVCP are applied and that the product fulfils all the prescribed requirements set out above. This certificate was first issued on **01/07/13** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Name:- Paul Duggan




Certification Manager